

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0328:0194 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models PSA and PSHA photoelectric type smoke detectors. Model PSHA employs a supplemental heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 22-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units when used in conjunction with listee's Models AB-4, AB-6, ASB, AIB and ARB bases. Models with supplemental heat sensor are not approved for use in lieu of the required heat detectors.

12-23-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2012**

Listing Expires **June 30, 2013**

Authorized By: **JASON DEWITT, Deputy State Fire Marshal**
Fire Engineering Division